




Latest achievements promoting heat pumps in Finland: energy carrier factors and ESBO freeware

2.6.2010 Jarek Kurnitski


Senior Lead, Built Environment
Sitra, the Finnish Innovation Fund
Adjunct Professor, Aalto University

Energy Programme 2008-2012




EPBD 2002, EuP 2005, RES 2008, EPBD recast 2010 have resulted regulation revisions in 2-3 years interval

Source: Kurnitski J. Contrasting the principles of EP requirements and calculation methods in EU member states. *REHVA journal*, December 2008, 22–28.



- Situation in the member states after EPBD implementation in June 2008 regarding EP requirements for new buildings and calculation methods
- In the figure, the most developed available calculation method is shown; in many countries simplified methods may be used in parallel or for some building type

Example of component based regulation: limited control on energy use and CO₂-emissions



- Component based regulation in Finland: detached houses both with 146 and 78 kWh/(m²a) electricity use comply with 2010 building code!
- Emission based/primary energy requirements to be launched in 2012


EP-value comparison in 2008

- How much delivered energy may be used in houses?
- Denmark (DK):
 - Primary energy $70 + 2200/A_{\text{gross}}$ kWh/(m²a)
 - The value does not include the household electricity
 - Primary energy factor 2.5 for the electricity and 1.0 for oil and gas
- Sweden 2006 (S):
 - Delivered energy 110 kWh/(m²a) (130 kWh/(m²a) in North region)
 - 75 kWh/(m²a) (95 in North) in the case of electrical heating (2010: 55 and 75)
 - The values do not include the household electricity
- Norway (N):
 - Delivered energy $125 + 1600/A_{\text{heated}}$ kWh/(m²a) in detached houses and 120 kWh/(m²a) in apartment buildings
 - The values include household electricity of 40 kWh/(m²a)
- Estonia (EST):
 - Primary energy 180 kWh/(m²a) which includes household electricity; $180 - 38 = 142$ primary energy without household electricity
 - Primary energy factor 1.5 for the electricity and 1.0 for oil and gas
- Germany (D):
 - Primary energy $130 + 2600/(100 + A_{\text{heated}})$ kWh/(m²a) (without household electricity) (2009 new)
 - Primary energy factor 2.7 for the electricity and 1.1 for oil and gas
- Finland 2007 (FIN):
 - Requirements for components only, so the value depends on the building (2010: -30%, +2012)

EP-value comparison


Source: Kurnitski J. Contrasting the principles of EP requirements and calculation methods in EU member states. *REHVA journal*, December 2008, 22–28.

- As requirements are both for primary (DK, EST, D) and delivered (S, N) energy, only the delivered energy can be compared
- DK, S & D do not include household electricity, therefore this is reduced from the values of EST & NOR
- 140 m² house is considered as EP-value depends slightly on heated area in DK, N & D
- Electricity use of 3 kWh/(m²a) for fans of ventilation and 5 kWh/(m²a) for circulation pumps of water based heating (0 kWh/(m²a) for electrical heating) is assumed
- The figure shows maximum allowed **delivered energy without household electricity** (i.e. delivered energy to heating, hot water and ventilation systems) in each country for fossil fuel or electrical heating




EP-value, degree-day corrected data

- Assumptions for degree-day correction:
- Energy use for hot water heating 25 kWh/(m²a)
- Electricity use of 3 kWh/(m²a) for fans of ventilation and 5 kWh/(m²a) for circulation pumps of water based heating (0 kWh/(m²a) for electrical heating)
- Remaining space heating energy is corrected with degree-days calculated from ASHRAE 2001 data; 17°C degree-days used:
 - 2917 Berlin, 3259 Copenhagen, 3894 Oslo, 3963 Stockholm, 4240 EstoniaTRY, 4422 °Cd Helsinki
 - the values are corrected to Copenhagen



EP-value, heat pumps

- To compare requirements for houses with heat pumps the net energy demand for space heating (ventilation heating included) and hot water heating should be compared
- Maximum allowed net energy demand is calculated for each country
- Seasonal energy efficiency ratio of 3.5 is used for the heat pump
- Results:
 - In N and FIN heat pumps cannot be taken into account
 - In DK, the net energy increase is 3.5/2.5 compared to delivered energy, i.e. quite modest due to 2.5 primary energy factor for electricity
 - S has no primary energy factors, so the increase is by 3.5



EPBD recast 2010

Roadmap to improved energy performance:

- Setting of minimum energy performance requirements based on calculation of **cost-optimal** levels :
 - The Commission shall establish by 30 June 2011 a comparative methodology framework
 - Member states shall report by 30 June 2012
- After 31 Dec 2018, public authorities that occupy and own a new building shall ensure that the building is a **nearly zero energy** building
- By 31 Dec 2020, all new buildings are **nearly zero energy** buildings
- Setting of minimum energy performance requirements for **major renovation**:
 - The threshold of 1000 m² is deleted
 - The definition of 'major renovation' is by the investment that should be more than 25% of the whole buildings value, excluding the land, e.g. the actuarial value, or more than 25% of the building envelope undergoes structural renovation


Finnish case study to determine emission based energy carrier factors including demand-capacity coupling effects

- CO₂-emissions from electricity generation and district heat production:
 - Hourly data of specific emissions from 2000-2007
 - Demand change analyses for electricity use
 - Demand change analyses for district heating use
 - Coupling with new capacity – scenarios
 - Derivation of **energy carrier weighting factors** based on energy system scenario calculations to show how much one energy carrier is causing more emissions than another

Source: Kurnitski J, Keto M. Accounting CO₂ emissions for electricity and district heat used in buildings – a scientific method to define national energy carrier factors. CLIMA 2010, 10th REHVA WORLD CONGRESS “Sustainable energy use in buildings”, 9–12 May 2010, Antalya, Turkey


Primary Energy Factors of Electricity Generation in Europe in 2006

source: Eurostat 2009 (Eurostat primary energy conventions), non-renewable only




Specific CO₂-emissions of Electricity Generation in Europe in 2006

sources: Eurostat 2009 (IPCC default emission factors)



Non-renewable primary energy factors in Finland (blue electricity and red district heat)



Why primary energy factors are almost constant in the long run?

- Major changes in Finnish energy production until 2030:
 - Significantly increased share of nuclear energy
 - CHP is used as much as today, almost constant district heat production
 - Increased use of renewables (wind, bio, solar), as much as technically feasible, but still less dominating than nuclear or CHP
- With IEA and Eurostat definition, primary energy equivalent of nuclear and conventional condensing power very similar, so, the compensating of condensing power will even slightly increase primary energy factor (40% vs. 33% efficiency)
- \Rightarrow cutting emissions with nuclear energy has no effect on primary energy factor...


Just use average specific emission factors?

- Average specific CO₂-emissions 2000-2007:
 - 273 kg(CO₂)/MWh) for electricity
 - 217 kg(CO₂)/MWh) for district heat
- Or average relative energy carrier factors (previous ones divided by reference specific emission of oil 267 kg(CO₂)/MWh)):
 - 1.0 for electricity
 - 0.8 for district heat
 - (reference: 1.0 for oil)
- These average factors would probably lead to increased use of electricity in buildings (electrical heating etc.) as **1.0** is very low compared to common primary energy factor of **2.5** for electricity
- What was not taken into account?

Higher factor for electricity in winter?



- Hypotheses: peak loads cause higher specific emissions in the production
- Can be easily tested with hourly data

Specific CO₂ emissions of total electricity generation as a function of outdoor temperature 2006–2008



- Generation of separate conventional thermal power in Finland can be high in summer period due to shortage of hydro power and lack of CHP which is generated against heat load of district heating + service breaks of nuclear power plants


Demand change analyses (emissions response to a step change in the demand)



Change in emissions ?

- In the electricity production especially carbon-neutral capacity is limited
- District heat CHP is produced against heat load without similar lack of capacity (demand change has no effect on the specific emission)
- Construction of new buildings or renovation of existing ones means changes in the demand responded by electricity market
- To account emissions of the step change we need to know a link between a new or non-appearing energy use in a building and energy production source (i.e. which type of plant will generate or is cutting down this energy production)
- These analyses resulted with **electricity factor for demand change 3 times higher than the average electricity factor**


Energy carrier factors for selected scenarios



How to quantify the factors between average and demand change values?

Demand change in district heating energy use

- The total CO₂ emissions of Finnish electricity generation and district heating production **if electricity use is kept constant**, but district heating is reduced (e.g. additional insulation of existing multi-storey buildings) or increased
- ⇒ Due to CHP, the total emissions do not depend on the amount of district heat used




Ratio of the district heat demand change (1 = current situation,
0.5 = 50% reduction, 1.5 = 50% increase)

■ Electricity generation

■ District heat production

District heat replacing electricity use or vice versa

- The **total use of electricity and district heat is kept constant:**
 - The ratio of 1 corresponds to the current situation, the ratio 0.5 means that half of current district heating energy used is replaced by electricity use and 2 that the current district heating use is doubled and electricity use reduced correspondingly
- ⇒ Replacing district heat by electrical heating drastically increases total emissions



Demand change analyses with flexible capacity

- Main principle: **energy system model allowing both changes in the demand and production capacities**, annual balance calculation
 1. Select reference electricity and district heat production (e.g. 90 TWh el. and 33 TWh DH, repeat the calculation for other relevant values)
 2. Define rules for production sources/capacities allowing to introduce new capacity to cover increased demand:
 - production sources with fixed capacity, hydro and nuclear (fixed capacity can be selected as input parameter)
 - production sources with flexible capacity, in this case condensing power and CHP
 - limits for district heat produced by CHP, 70...80% in this case
 - wind power and solar electricity fixed in this case, but can be treated with similar rules if considered flexible
 3. Introduce a step change of heat and electricity demand (+3 TWh in this case) and solve energy production balance by minimizing emissions or production cost
 4. Results: emissions and cost caused by +3 TWh electricity or heat production \equiv specific emission factors of the studied scenario


Finnish case study

- +3 TWh step change of heat or electricity demand
- 80 and 90 TWh reference electricity production and 33 TWh district heat production
- Flexible capacity of separate condensing power and CHP
- Nuclear energy capacity fixed, several capacity values calculated
- Hydropower and wind power fixed
- Limits for district heat produced by CHP, to be between 70 and 80%

Specific emission (energy method) and cost data used:

Production source	Fuel cost milj. EUR/TWh	Specific emission kgCO ₂ /MWh
Nuclear energy	5	0
Separate condensing power	25	900
CHP electricity	15	300
CHP district heat	18	300
Separate district heat	22	225

Emissions by + 3 TWh with flexible capacity



- + 3 TWh electricity increased emissions by factor of 4,0 relative to + 3 TWh district heat (0.68 Mt vs. 2.7 Mt)
- This factor of 4 would change to 3, if separate district heat production is not used
- Results confirm that relevant selection of energy carrier factor for electricity should be **close to the demand change values**, not average values of specific emissions

Energy carrier factors: conclusions

- Specific CO₂-emissions factors are scientifically sound (independent on definitions), but average factors cannot be used for regulative purposes, because they may guide to increased electricity use, which will consequently increase emissions as shown in the Finnish case study
- Finnish average specific emission based factors (2000-2007):
 - **electricity 1.0, district heat 0.8 and oil 1.0** (reference)
- Average factors for electricity and district heat are very close, but **replacing district heat by electrical heating drastically increased total emissions in the Finnish case study and vice versa**
- Hourly demand change allocation increased electricity factor from **1.0 to 3.0** and analyses both with fixed and flexible capacity showed that the factor caused by demand change is 3 to 4 times higher than the average one
- Proposed factors for Finland

Electricity	2.0
District heat	0.7
District cooling	0.4
Fossil fuels	1.0
Renewable fuels	0.5

ESBO – Early Stage Building Optimization

- Promoting indoor climate and energy simulation
- **Freeware, stand-alone tool**
- Fixed geometries for many building types
- Full access to modify building envelope properties (windows, walls, solar shading etc.)
- Highly developed technical building systems:
 - HVAC (all common systems)
 - Heat pumps (all types)
 - Solar thermal and solar electrical
- Easy to use, just drag and drop of components and systems
- Coming soon! Beta already available



<http://www.equaonline.com/esbo/>

Selection of systems: drag and drop + double click to modify parameters

The screenshot displays the IDA Indoor Climate and Energy software interface. On the left, a sidebar titled "Insert new object" lists various system categories and their generic components:


- Solar thermal**: Generic solar thermal
- Photovoltaics**: Generic photovoltaics
- Ventilation**: Standard AHU, Return air only AHU, AHU with electrical heating coil
- Topup heating**: Generic topup heater
- Base heating**: Ambient air to water heat pump (highlighted)
- Hot storage**: Generic hot water tank
- Cold storage**: Generic cold water tank
- Cooling**: Generic chiller
- Ground heat exchange**: Ground heat exchange
- Domestic hot water**: Generic domestic hot water
- Energy**: Generic electricity rate, Generic fuel rate, Generic district heating rate, Generic district cooling rate, Generic CO2 emission factors, Generic primary energy factors

The main window, titled "building1: building1.idm", shows the configuration for a project named "building1". It includes tabs for "Rooms", "Building", "Start simulation", "Results", and "Outline". The "Building" tab is active, displaying various system configuration panels:

- Global data**: Location (Espoo), Wind profile (Default urban), Rotate building (15.0° Clockwise), and links to Project data, Defaults, Thermal bridges, Ground properties, Infiltration, Extra energy and losses, and Building 3D and shading.
- Distribution systems**: Air (Constant supply air temperature: 16.0 °C), Heat (Room sup. T: 70.0 °C, AHU supply T 60.0 °C), and Cold (Room sup. temp: 14.0 °C, AHU supply temp 5.0 °C).
- Domestic hot water**: 0.0 L/per occupant and day.
- Energy**: Electricity rate (0.1 €/kWh), District heating rate (0.07 €/kWh), CO2 emission factors (No CO2 emission factors), Fuel rate (0.08 €/kWh), District cooling rate (0.07 €/kWh), and Primary energy factors (E: 2.0 F: 1.0, DH: 0.7 DC: 0.4).
- Central systems**: A diagram showing the integration of various systems. The diagram includes:
 - Solar thermal**: No solar thermal
 - Photovoltaics**: No photovoltaics
 - Ventilation**: Standard AHU
 - Topup heating**: Generic district heater (Efficiency (COP): 1, Capacity: Unlimited)
 - Base heating**: Ambient air to water heat pump
 - Cooling**: Generic electric chiller (COP (EER): 3, Capacity: Unlimited)
 - Hot storage**: Generic hot water tank (Volume: 1 m3)
 - Cold storage**: Generic cold water tank (Volume: 1 m3)
 - Ground heat exchange**: Ground heat exchange not yet implemented

Example of model buildings

(detached houses, apartment buildings, office, school, sport and industrial hall available)



- Example of heat pump model:
 - select the model from the list or fill in performance data at rating conditions

The screenshot shows a software window titled "A2Wheatpumpmodel". Inside, there's a dropdown menu showing "A2Wheatpumpm" and "A2WHeatPumpModel". The main section is titled "Ambient air to water heat pump". It contains two sub-sections: "Main parameters at rated conditions" and "Additional settings at rated conditions".

Main parameters at rated conditions:

- Total heating capacity: 7.951 kW
- COP (incl. outdoor fan): 3.620067 0-10

Additional settings at rated conditions:

- Compressor type: ctReciprocating
- Outdoor (cold) unit:
 - $T_{db_air_in} - T_{db_air_out}$ (excl. fan dT): 12.64 °C
 - $T_{air} - T_{evaporator}$: 5.5 °C
 - SHR (sensible/total cooling power): 0.771 0-1
 - Fan pressure rise: 100 Pa
 - Fan efficiency: 0.5 0-1
- Water (hot) unit:
 - $T_{condenser} - T_{water}$: 6.6 °C

At the bottom right of the main section is a button labeled "Rating contitions". At the bottom of the window are four buttons: "OK", "Cancel", "Save as...", and "Help".

Export to IDA-ICE (commercial) for advanced users

Plant with tanks

Plant model with (by default) very large capacity. Supply hot water setpoint is a function of outside air temp. Chilled water temperatures to zones and AHU are constant.

