



Assessment of ambient loop-coupled GSHP and WWHP systems in a cold-climate institutional/residential development

M. Brands¹, U. Sohail, & A. S. Fung

¹ Faculty of Engineering and Architectural Science, Toronto Metropolitan University

350 Victoria St., Toronto, ON, M5B 2K3, Canada

mbrands@torontomu.ca



Podium/tower development



- 44-storey residential tower
- 15-storey podium: 1 mechanical floor, 14 floors of academic/commercial space (retail, café, science gallery, study rooms, classrooms, laboratories)
- 62,297 m² (702,850 ft²) floor area
- Downtown core location on campus of **Toronto Metropolitan University** in Ontario, Canada
- Energy modelling performed in **eQuest** by consultants employed by the University




- Residential and commercial buildings account for almost **30% of secondary (end-user) energy use** in Canada [1]
- 81% of residential energy consumption goes towards space and water heating [1]
- Canada aims to reduce GHG emissions 40% below 2005 levels by 2030; net-zero by 2050
- Carbon pricing set to increase to \$170/tonne CO₂eq by 2030
- Generation intensity of Ontario grid is 25 g CO₂e/kWh (compare Illinois at 314 g CO₂/kWh) [2] [3]



Systems modelled




- Base case (natural gas boilers and water-cooled chiller)
- Conventional ambient loop (ambient loop coupled with open-loop cooling tower and natural gas boilers)
- Ambient loop-coupled **wastewater heat pump**
- Hybrid wastewater heat pump/conventional ambient loop
- Ambient loop-coupled **ground-source heat pump**
- Hybrid ground-source heat pump/conventional ambient loop




Ambient loops

- Ambient or near-ambient temperatures (8-25°C)
- Possibility of simultaneous heating and cooling



WWHP


- Urban sewers have high flows, ambient or near-ambient temperatures



GSHP

- Soil used as heat source/sink
- Average ground temperatures of 5-15°C

- Base, conventional AL, and both WWHP systems modelled in **Microsoft Excel** using **XSteam** and **Psych** plugins
 - Water-cooled chiller data acquired from manufacturer
 - TRNSYS water-to-air heat pump performance data used
 - Open-loop cooling tower model created
 - Available energy for WWHP estimated using flow data provided by Toronto Water (non-adjacent sewer), sewer temperature correlation



- GSHP systems modelled in Hybrid Ground-Coupled Heat Pump (“**HyGCHP**”) software (TRNSYS-based software package)

Ground temperature	13.9°C	Ambient loop fluid	Propylene glycol
Drilling depth	91.4 m	Minimum fluid temperature	-7.78°C
Bore spacing	6.10 m	Pump power per 100 tons of peak block load	7,457 W
Header depth	1.80 m	Fraction of pressure drop attributable to GHX	0.55
Center-to-center half distance	3.80 cm	COP heating	3.42
Borehole radius	5.70 cm	EER cooling	15.6 MBH/kW
Ground thermal diffusivity	0.10 m	Fan operation	Continuous
Ground thermal conductivity	5.68 W/m ² -K	Performance curves	Default
U-tube size	25 mm	Heating EAT	21°C
Grout thermal conductivity	4.54 W/m ² -K	Cooling EAT	24°C

System	Energy use (MWh)	GHG emissions (tonnes)	Cost (\$ CAD, 2019)	Cost (\$ CAD, 2030)
Base	13,193	2,118	\$630,450	\$987,149
Conventional AL	9,566	1,236	\$689,332	\$897,107
WWHP	5,711	171	\$866,423	\$894,409
WWHP-Conventional	6,007	589	\$582,861	\$681,656
GSHP	3,261	97	\$494,646	\$510,623
GSHP-Conventional	3,218	96	\$488,123	\$503,889



Conclusions



- GSHP systems (hybrid and non-hybrid) outperform all other systems in **energy use, GHG emissions, and cost** (2019 and 2030 energy costs)
- By 2030, the base case has higher energy costs than any of the other five systems – result of scheduled Canadian carbon pricing increase
- Economics favour increasing adoption of heat pump systems



Limitations of present study, future work



- Asymmetry in modelling of different systems; GSHP-specific software packages tend to **overestimate the long-term performance of GSHP** systems
- Limited space for GSHP systems in dense urban areas
- Flow data from adjacent sewers required to accurately estimate available wastewater energy
- Capital cost comparison needed to fully assess economic feasibility of all systems under consideration



Works cited



1. Natural Resources Canada, *Energy Fact Book 2021-2022*, 2021.
2. Environment and Climate Change Canada, *National Inventory Report 1990-2020: Greenhouse Gas Sources and Sinks in Canada*, 2022.
3. U.S. Energy Information Administration, “Illinois Electricity Profile, 2021.” [Online.] Available:
<https://www.eia.gov/electricity/state/illinois/> [Accessed 2023-05-03]



Thank you!

Questions?

Monica Brands <mbrands@torontomu.ca>

The authors would like to thank **Noventa Energy Partners** and **Mitacs Accelerate** for their generous support of this research, as well as **Toronto Metropolitan University** for providing building-related data.